

Plot Date:	18 December 2020 - 12:34 AM

Date

No Revision

Dec. 2020

1. Pavement construction shall be in accordance with but not limited to the following VicRoads Sections:

- 100 Series General
  - 173 Examination and Testing of Materials and Work (Roadworks)
- 200 Series Formation
- 300 Series Flexible Pavements
  - 304 Unbound Flexible Pavement Construction
- 306 Cementitious Treated Pavement Subbase
- 310 Preparation of Granular Pavements for Bituminous Surfacing
- 400 Series Asphalt and Surface Treatments
  - 407 Hot Mix Asphalt
  - 409 Warm Mix Asphalt
- 800 Series Materials
- 2. Pedestrian pavement construction must comply with grading requirements set out in Australian Standard AS1428.
  - All dimensions are in millimetres unless noted otherwise.

1. Class CC2 recycled crushed concrete in accordance with VicRoads Standard Section 820 - Crushed Concrete for Pavement Subbase and Light Duty Base may be substituted for Class 2 crushed rock.

2. Reclaimed asphalt pavement (RAP) may be used in Council footpaths, in accordance with the requirements and limitations of VicRoads Standard Section 407 - Hot Mix Asphalt. Where Warm Mix Asphalt is approved for use, asphalt pavements shall be in accordance with VicRoads Standard Section 409 and Section 407.

Asphalt finishes should be consistent in appearance and be level and flush with existing pavement surfaces.

The use of other selected recycled materials in road pavements can be implemented in accordance with Table A of VicRoads Technical Note TN 107 - Use of Recycled Materials in Road Pavements where applicable.

Refer CPP 2201 for service trenching.

- Where footpath trench or pit construction works affects more than 50% of the bays the entire bays to be replaced.
- Reinstatement level to match existing levels.
- For any further clarification to contact Council Asset protection officer.

 Drawing Title FOOTPATH PAVEMENT ASPHALT				
Original Size	Drawing No:	CPP1301	Rev:	A